

Design No. G504


March 10, 2020

Restrained Assembly Rating — 2 Hr.

Unrestrained Assembly Rating — 2 Hr.

This design was evaluated using a load design method other than the Limit States Design Method (e.g., Working Stress Design Method). For jurisdictions employing the Limit States Design Method, such as Canada, a load restriction factor shall be used — See Guide [BXUV](#) or [BXUV7](#)

* Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.



1. **Normal-Weight Concrete** — Carbonate or siliceous aggregate, 150 + or - 3 pcf unit weight, 4000-psi compressive strength.

2. **Metal Lath** — 3/8 in. rib, 3.4 lb/sq yd expanded steel; tied to each joist at every other rib and midway between joists at side lap with 18 SWG galv steel wire.

As an alternate, the form material for the concrete may be corrugated steel deck 9/16 in. deep of 28 MSG (minimum) galv steel welded to supports 15 in. O.C. with washers. The concrete thickness shown in Part 1 shall be measured to the top plane of the steel deck.

3. **Steel Joists** — Type 10J3 min size; spaced 24 in. O.C. and welded to end supports.

4. **Horizontal Bridging** — 1/2 in. diam continuous steel bar stock; welded to top and bottom chord of each joist.

5. Furring Channels — No. 25 MSG galv steel, 2-7/16 in. or 2-9/16 in. or 2-23/32 in. wide at top and 1-7/16 in. wide at bottom by 7/8 in. deep; spaced at 24 in. O.C. perpendicular to joists except at wallboard end joints as noted below. Additional channel 75 in. long, positioned at each end joint of wallboard, 2-1/2 in. O.C. from the continuous channel. Channels secured to each joist with 18 SWG galv steel wire bent into double strand saddle ties. Channels spliced by overlapping adjoining pieces 6 in., and securing together with double strand of 18 SWG tie wire at exposed end of channel. Splices to occur below joists and to be tied to lower chords of joists with an additional double strand of the tie wire.

As an alternate, furring channels may be secured to 1-1/2 in. cold-rolled channels at every intersection with double strand of 18 SWG galv wire. Cold-rolled channels spaced 24 in. OC and suspended perpendicular from lower chords of joists with 8 SWG galv wire spaced 48 in. OC along channels.

5A Steel Framing Members* — (optional, not shown) — alternate method to attach furring channels (Item 5) to joists (Item 3). Clips spaced 48 in. OC., and secured to alternating joists with cup washer installation kit provided by manufacturer. On underside of bottom chord, 1-1/2 in. dia x 3/8 in. deep No. 16 galv steel cup washer is placed to surround the rubber insert. Clip attached to the bottom chord with a 1/4 in. dia. zinc plated bolt inserted through the center grommet and between the chord members; depth of bolt determined as 1-1/2 in. plus the depth of the bottom chord of the joist. Fastened on the top side of the bottom chord with a second cup washer placed open side up, and a 1/4 in. zinc plated "Nyloc" nut. Furring channels are friction fitted into clips. RSIC-1 clip for use with 2-9/16 in. wide furring channels. RSIC-1 (2.75) clip for use with 2-23/32 in. wide furring channels. Ends of adjoining channels are overlapped 6 in. and tied together with double strand of No. 18 SWG galv steel wire near each end of overlap. As an alternate, ends of adjoining channels may be overlapped 6 in. and secured together with two self-tapping No. 6 framing screws, min. 7/16 in. long at the midpoint of the overlap, with one screw on each flange of the channel. Additional clips required to hold furring channel that supports the wallboard butt joints, as described in Item 6.

PAC INTERNATIONAL L L C — Types RSIC-1, RSIC-1 (2.75).

5B. Steel Framing Members* — (Optional, Not Shown) - Used as an alternate method to attach furring channels (item 5) to joists (item 3). Clips spaced at 48" OC and secured to the bottom of the joists with cup washer installation kit provided by manufacturer. On underside of bottom chord, 1-1/2 in. dia x 3/8 in. deep No. 16 galv steel cup washer is placed to surround the rubber insert of clip. Clip attached to the bottom chord with a 1/4 in. dia zinc plated bolt inserted through the center grommet and between the chord members; depth of bolt determined as 1-1/2 in. plus the depth of the bottom chord of the joist. Fastened on the top side of the bottom chord with a second cup washer placed open side up, and a 1/4 in. zinc plated "Nyloc" nut. Furring channels are then friction fitted into clips. Ends of channels are overlapped 6" and tied together with double strand of No. 18 AWG galvanized steel wire. Additional clips are required to hold the Gypsum Butt joints as described in Item 6.

STUDCO BUILDING SYSTEMS — RESILMOUNT Sound Isolation Clips - Type A237R

6. Gypsum Board* — 1/2 in. thick, installed with long dimensions perpendicular to furring channels and side joints located midway between joists. End (butt) joints to be staggered and centered between the two furring channels which are spaced 2-1/2 in. OC. Wallboard fastened to furring channels with wallboard screws spaced 8 in. OC each side of every end joint and 12 in. OC in each row screws in the field of each board. Screws adjacent to wallboard joints respectively located 1-1/4 in. and 1-1/2 in. from end and side joints. Joint treatment not required for this rating, except for tapered, rounded-edge wallboard where edge joints are covered with paper tape and joint compound. As an alternate, nom 3/32 in. thick gypsum veneer plaster may be applied to the entire surface of Classified veneer baseboard. Joints reinforced.

When **Steel Framing Members** (Item 5A) are used, wallboard butt joints shall be staggered min. 2 ft. within the assembly, and occur between the main furring channels. Edge joints may occur beneath the joists. At the wallboard butt joints, each end of the gypsum board shall be supported by a single length of furring channel equal to the width of the wallboard plus 6 in. on each end. The furring channels shall be spaced approximately 3-1/2 in. OC, and be attached to underside of the joist with one RSIC-1 clip at each end of the channel. Gypsum board attached to the

furring channels using 1 in. long Type S bugle-head steel screws spaced 8 in. OC along butted end joints and 12 in. OC in the field of the board. Wallboard joints covered with fiber tape and joint compound.

When **Steel Framing Members** (Item 5B) are used, gypsum board is installed with long dimensions perpendicular to furring channels. Gypsum board secured to furring channels with nom 1 in. long Type S bugle-head steel screws spaced 8 in. OC in the field of the board. Gypsum board butted end joints shall be staggered minimum 48 in. and centered over main furring channels. At the gypsum board butt joints, each end of each gypsum board shall be supported by a single length of furring channel equal to the width of the gypsum board plus 3 in. on each end.. The two supporting furring channels shall be spaced approximately 3 in. in from end joint. Screw spacing along the gypsum board butt joint and along both additional furring channels shall be 8 in. OC. Additional screws shall be placed in the adjacent section of gypsum board into the aforementioned 3 in. extension of the extra butt joint channels as well as into the main channel that runs between. Butt joint furring channels shall be attached with one RESILMOUNT Sound Isolation Clip at each end of the channel.

AMERICAN GYPSUM CO — Type AG-C

CABOT MANUFACTURING ULC — Type C

CERTAINTED GYPSUM INC — Type C

CONTINENTAL BUILDING PRODUCTS OPERATING CO, L L C — Type LGFC-C/A.

GEORGIA-PACIFIC GYPSUM L L C — Types 5, C, GPFS1, DAP, DA, DAPC, TG-C.

NATIONAL GYPSUM CO — Types FSK-C, FSW-C.

PABCO BUILDING PRODUCTS L L C, DBA PABCO GYPSUM — Types PG-1, PG-3, PG-C.

THAI GYPSUM PRODUCTS PCL — Type C

7. **Screw, Wallboard** — No. 6 Phillips-type (flathead) self-drilling and self-tapping, 1 in. long. Screw heads may be exposed or covered with joint compound. Screws shall be driven no farther than slightly indented (not deeper than 1/64 in.) into the exposed surface of the wallboard.

*** Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.**

[Last Updated](#) on 2020-03-10